



ITEM # FIRE SUPPRESSION SYSTEM
Quantity: Lot, (1)
Spec. Manufacturer: Hochiki America Corporation, Phone: (714) 522-2246
Spec. Model No.: Avenger K Restaurant Fire Suppression System (UL-300)
Pertinent Data: Pressurized thermal responsive tubing detection system or Mechanical detection utilizing fusible links
Utilities Required: 120V – 1Ph, 20 Amps;

Furnish and set in place as per manufacturer's standard specs and the following:

GENERAL CONDITIONS:

1. The Fire Protection Contractor shall be a Factory Authorized, Factory Trained and State Certified Distributor of the Hochiki America Corporation general product line. The Fire Protection Contractor must also hold a current Hochiki America Corporation certificate in an "Avenger K" training program.
2. The Fire Protection Contractor shall maintain a minimum of a 1-Million Dollar Liability Policy to insure all work performed.
3. All installations must meet current UL-300 criteria; the latest NFPA 96 and NFPA17A (wet chemical) guidelines.
4. The fire suppression system shall include a minimum 3-year manufacturer's warranty to cover the entire system. The warranty shall be valid only if the system is installed, serviced and maintained by a Hochiki America Corporation authorized distributor in strict accordance with Hochiki America Corporation Manual No. HA-06-362.
5. The Fire Protection Contractor shall include a minimum 1-year installation warranty to cover the entire system.
6. The Fire Protection Contractor shall provide as part of the fire suppression system a Hochiki America Corporation mechanically operated BRASS gas valve. **GENERIC GAS SHUT-OFF VALVES SHALL NOT BE ACCEPTABLE-** The plumbing contractor shall be responsible for the proper installation of the gas valve.
7. The Fire Protection Contractor shall furnish and install all appliance drops to be penetrating through the top of the hood with a UL-approved Quick Seal device and aimed as directed by the Hochiki America Corporation installation manual No. HA-06-362.
8. All exposed appliance drops shall be chrome-plated.

9. The General Contractor shall schedule the installation of the recessed remote pull station(s) with the Fire Protection Contractor @ 4'-6" above the finished floor.
10. The Fire Protection Controller shall provide a dry-contact micro-switch as required to actuate shut-down of the make-up air fan, remove power to all energized electrical sources under the hood, and signal building fire alarm where fire alarm is present.
11. The fire suppression system's extinguishing agent shall be a Hochiki AK liquid fire suppressant, a potassium acetate based solution that suppresses cooking grease fires through both saponification and cooling. The agent shall have a pH of 9 or less and will not harm stainless steel.
12. All related electrical connections and devices shall be provided and installed by the Electrical Contractor.
13. KEC and General Contractor to coordinate with local authorized Hochiki America Corporation/Fire Protection Specialist for products, installation, and system certification.
14. Unit shall be housed in stainless steel cabinet. Verify drawing for actual location.

PRODUCT DATA:

1. The Hochiki America Corporation "Avenger K" Fire Suppression System is a pre-engineered, fixed, automatic fire suppression system that when pneumatically or mechanically activated discharges a fixed amount of wet chemical agent.
2. The system shall be the pre-engineered type having minimum and maximum guidelines established by the manufacturer and listed by Underwriters Laboratories, Inc. (UL).
3. The manufacturer shall be ISO 9001-2000 registered.
4. The wet chemical agent shall be a specially formulated, aqueous solution of inorganic salts with a pH less than 9 and shall be designed for rapid flame knockdown and foam securement of grease-related fires.
5. Provide all components, including recessed manual pull station(s) as required for a completely operable system.
6. This pre-engineered Hochiki America Corporation "Avenger K" fire suppression system shall be warranted for not less than three years from the date that it has been certified for use. (See the manufacturer's Limited Warranty for further information)
7. Must meet all applicable federal, state and local laws, rules, regulations and codes.