

## AS2010-00

### ADDRESSABLE FIXED TEMPERATURE / RATE OF RISE HEAT DETECTOR



#### Standard Features

- Low Profile - Only 2.0" high, including base
- Simple and reliable device addressing
- 2 in 1: Fixed Temperature / Rate of Rise Detector
- Uses the noise-immune Digital Communication Protocol (DCP), which utilizes interrupts for fast response to fires
- Two built-in power/alarm LEDs
- Programmable non-polling LEDs
- Rate of rise temperature threshold: 15°F/Min (determined by panel)
- Adjustable threshold temperature: 135°F to 190°F
- UL maximum spacing of 70 feet

**NOTE:** Bases are not included with detectors, please order separately.

#### Application

The AS2010 Fixed Temperature / Rate of Rise sensors provide accurate temperature measurement data to the fire alarm control panel. These sensors are well-suited for environments where dust, cooking fumes or other factors make the use of smoke sensors impractical.

#### Operation

The AS2010 incorporates a highly linear thermistor circuit. The specially designed cover protects the thermistor while allowing maximum air flow. The thermistor circuit produces a voltage proportional to the temperature; this information is transmitted to the control panel as a digital value. When the ambient temperature exceeds a preprogrammed threshold (fixed temp or rate of rise), the sensor transmits an interrupt to the control panel indicating a fire alarm. The fire alarm control panel can adjust the sensor's fixed temperature threshold for different installation requirements.

Up to 127 devices may be installed on each SLC loop. The sensor address may be set by a hand-held programming unit. The sensor mounts to an electronics-free base and incorporates a locking mechanism for security. The base provides mounting slots, terminals for field wiring and a third terminal for a remote indicator/ LED. The sensor has dual LEDs for easy viewing of the sensor status.



## Sensor Spacing

Heat sensor spacing shall be in compliance with NFPA 72. The distance between heat sensors shall not exceed their listed spacing or all points on the ceiling shall have a sensor within a distance equal to or less than 0.7 times the listed spacing. Heat sensors shall be located within a distance of one-half the listed spacing, measured at right angles from all walls or partitions extending upward to within the top 15 percent of the ceiling height. For additional instructions see NFPA 72.

## Engineering Specification

Heat sensors are installed in accordance with NFPA (National Fire Protection Association) 72, the UL Listed Spacing Requirements and the rules and regulations set forth by the local authorities having jurisdiction.

The contractor shall furnish and install, where indicated on the plans, Fixed Temp / Rate of Rise Automatic heat sensors.

The Sensor and Base shall be UL listed as compatible with the fire alarm control panel (FACP). The base shall permit direct interchange with the Avenger AS2011 photoelectric smoke sensor, AS2010 heat sensor, and the AS2012 / AS2014 Multi-Criteria sensors.

The vandal-resistant, security locking feature shall be used in those areas as indicated on the drawing. The locking feature shall be optional and can be implemented when required.

It shall be possible for the control panel to perform a functional test of the sensor without heat. The test method shall simulate the effects of heat on the device to insure testing of internal circuitry.

## Bases

The AS7001 and the AS7002 mounting bases are electronics free and are a simple rugged design with screw terminals for wiring connections. A common mounting base allows sensor interchange and maintains loop continuity when sensors are removed. A simple anti-tamper head locking system is provided which is enabled by removing a small plastic tab on the back of the sensor. Once locked, the head can be removed using a small diameter screw driver.

## Technical Specifications

<b>Operating Voltage</b>	17 - 41 VDC
<b>Standby Current</b>	350µA
<b>Alarm Current</b>	500µA
<b>Transmission Method</b>	DCP (Digital Communication Protocol)
<b>Operating Temperature</b>	14°F to 122°F (-10°C to 50°C)
<b>Maximum Humidity</b>	Up to 95% non-condensing
<b>UL Temperature Range</b>	135°F to 190°F (57.2°C to 87.8°C)
<b>Rate of Rise</b>	15° F/Min. (8.3° C/Min.)
<b>UL Maximum Spacing</b>	70 Feet
<b>Color and Case Material</b>	Bone / White - ABS Blend
<b>Weight</b>	3.2 oz. (4.9 oz with 4" base)

## Ordering Codes

<b>AS2010-00</b>	Addressable Heat Detector
<b>AS7001-00</b>	4" Addressable Base
<b>AS7002-00</b>	6" Addressable Base
<b>AS7003-00</b>	4" Addressable Base with built-in Isolator
<b>AS7004-00</b>	6" Addressable Base with built-in Isolator
<b>AS7005-00</b>	Low Frequency Sounder Base
<b>AS7008-00</b>	Sounder Base
<b>AS8201-00</b>	Round Shape Remote LED Indicator
<b>AS8202-00</b>	Square Shape Remote LED Indicator