

## Electrical Signaling

Electrical protective signaling systems are configurations of components used to produce alarm signals indicative of fire, smoke, sprinkler waterflow or other emergency and to produce supervisory signals indicative of conditions needing attention with respect to protection equipment or watch service. System configurations are classified according to where and how the signals are received. The categories are commonly designated as local, municipal, remote station, proprietary, emergency voice/alarm communication, emergency communication, and central station. Auxiliary systems are either local or proprietary systems interconnected with a municipal system.

This category presents the major system component categories and the integrated system configurations. The selection of components to form a hybrid system should be made only by those skilled in system design. Also, the suitability of any system application should be judged on the basis of the hazard(s) being protected.

## Alarm Signal Initiating Devices

Alarm signals are initiated either automatically or manually. Automatic detectors respond to changes in characteristic phenomena associated with fire or other emergency conditions.

## Fire Detection, Heat-Actuated

Heat sensitive devices may be either "spot" or "line" type and operate at a fixed temperature or on a rapid increase in temperature (rate-of-rise). Some detectors combine the fixed and rate sensitive principles.

The spacing guides listed are indicative of each detector's relative sensitivity and, in each case, the spacing guide is the maximum recommended separation between detectors for smooth-ceiling installations. For a given temperature rating, a fixed-temperature detector which has a 30 ft (9 m) listing and one which has a 15 ft (5 m) listing will both respond at approximately the same time to a geometrically growing fire if each is installed at its listed spacing. FM Approved rate-of-rise detectors all have 30 ft (9 m) listed spacings, the maximum separation recommended by FM Approvals.

Installation of heat detectors at less than maximum spacing is necessary: to achieve earlier response; to compensate for ceiling obstructions such as beams and joists; and to compensate for ceiling heights greater than 15 ft (5 m). Proper location and use of heat detectors involves consideration of ceiling construction, the location of partitions, the maximum normal room temperature, heat produced by the occupancy, and whether detector function is to warn occupants or to automatically actuate protection equipment. Refer to Standard 72-1993 of the National Fire Protection Association and design specifications published by jurisdictional authorities, as appropriate.

## AS2010-00

### PR456304

AS2010-00 Fixed Temperature/Rate of Rise addressable heat detector. To be used with compatible Approved fire alarm control panels Avenger – Oasis 2 Loop, 4 Loop or Avenger – Oasis 1 Loop, 2 Loop models only. Up to 127 devices are permitted on each panel's signaling line loop. Uses models AS7001-00 and AS7002-00 detector bases. Fixed temperature heat detector operating range from 135°F (57°C) to 150°F (65°C) or the rate of rise response are being programmed from the control panel. RTI classification for detector is Quick with a 6 m x 6 m spacing (20 x20 ft) – when the sensor is set to alarm at 135°F (57°C) or programmed for a rate of rise response; and Fast with a 8 m x 8 m spacing (25 x25 ft) – when the sensor is set to alarm at 190°F (88°C). Operating voltage range of 17 to 41V dc, with the standby current at 450 µA and alarm current at 540 µA. Suitable for indoor use only (unheated, but not refrigerated areas) with temperatures from 14°F to 122°F (-10° to 50°C). Avenger – Oasis 2 Loop, 4 Loop or Avenger – Oasis 1 Loop, 2 Loop Fire Alarm Control Panels listings under Local Protective Signaling)

<b>Company Name:</b>	Avenger Systems, LLC
<b>Company Address:</b>	11586 Zagarolo Lane, Las Vegas, Nevada 89141, USA
<b>Company Website:</b>	<a href="http://www.avengersystems.com">http://www.avengersystems.com</a>
<b>New/Updated Product Listing:</b>	Yes
<b>Listing Country:</b>	United States of America
<b>Certificate Number:</b>	
<b>Certification Type:</b>	FM Approved