

UQGS.S35691 - Heat-automatic Fire Detectors

Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)**AVENGER SYSTEMS LLC**11586 Zagarolo Lane
Las Vegas, NV 89141 USA

S35691

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
AS2010-00 (a)	FT/ROR	D2	-	135-194	70	35
AS2020-00	FT/ROR	None	-	-	-	-
AS2021-00	FT/ROR	None	-	-	-	-
AS2035-00	FT/ROR	None	-	-	-	-
AS2036-00	FT	None	-	-	-	-
AS2037-00	FT	None	-	-	-	-

Base Model	Related Detector	Control Unit Compatibility Restrictions
AS2050-00, AS2051-00, AS2049		
	AS2020-00, AS2021-00, AS2035-00, AS2036-00, AS2037	None
AS7002-00, AS7001-00	AS2010-00	B2

B2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

FT/ROR - Fixed temperature/rate of rise combination

FT - Fixed temperature

(a) - Detector may be set for FT [Mode 0], FT/15° ROR [Mode 1] or 15° ROR [Mode 2] Operation.

Last Updated on 2015-11-23

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"